

Proposed amendment to 2021 IFC Section 319, add new section 319.2.1 Inspections.

319.2.1 Inspections. Submission of a passing inspection report, performed by another North East Fire Department Association (NEFDA) city (*Bedford, Grapevine, Southlake, Colleyville, Haltom City, Watauga, Euless, Hurst, North Richland Hills, Richland Hills, Roanoke, Trophy Club and Westlake*) who has adopted the 2021 International Fire Code, may be provided in lieu of receiving a fire inspection by Keller Fire-Rescue. To be considered a passing inspection, the inspecting entity shall enforce Sections 319 and 606 in their entirety, without amendments, in addition to the most currently published Editions of NFPA 17A, 96 and Appendix B of 96. A copy of the current Fuel Gas System test, as required by Section 319.10.3 shall be provided with the passing fire inspection submission. The passing NEFDA city inspection shall have been issued within the preceding thirty (30) days and the fixed-extinguishing system shall have an inspection tag that is current, and shall remain current. If the fixed-extinguishing system inspection expires during the permitted period (six-months) a new inspection will be required.