

Sec. 19-614. - Local discharge limits.

(a) The following pollutant limits are established to protect against pass through and interference and apply at the point where the wastewater is discharged to the POTW. No person shall discharge, or cause or permit to be discharged, wastewater containing in excess of the following instantaneous maximum allowable discharge limits.

(1) Toxic pollutants specified in the following table:

Toxic Pollutant	TRA Central Instantaneous Maximum Allowable Discharge Limits (mg/L)	TRA Denton Creek Daily Maximum Allowable Discharge Limits (mg/L)
Arsenic	0.2	-
Cadmium	0.1	0.044 0.047
Chromium	2.1	10.0
Copper	1.8	5.64 3.51
Cyanide	0.4	1.0
Lead	1.2	0.32 0.22
Mercury	0.06	0.005
Molybdenum	0.5	-
Nickel	3.3	2.91 2.98
Selenium	0.2	-
Silver	0.8	-
Zinc	6.1	2.80 2.99
Oil and Grease	200	100
Total Toxic Organics	-	2.13
pH	5.5-11.0 Standard Units	5.5-11.0 Standard Units

All concentrations for metallic substances are for "total" metal unless indicated otherwise. The director of public works may impose mass limitations in addition to, or in place of, the concentration-based limitations above.